5818 ROUTE 9H & 23 HUDSON, NY 12534

KEELER VAULT CO.

SEPTIC TANKS
DRY WELLS
D-BOXES
CATCH BASINS

STEPS
CURBING
WHEEL STOPS
CUSTOM WORK

PRECAST CONCRETE PRODUCTS

518-851-6281
518-851-9134
FAX 518-851-7835

MODEL 1000-P
STANDARD 1000 GALLON PUMP STATION
WITH SINGLE PUMP
WITH SS RAIL SYSTEM
3 INLETS 1 OUTLET

TOP VIEW



END VIEW



SIDE VIEW



WEIGHT: 9,310 LBS.

MAXIMUM RECOMMENDED DEPTH OF COVER OVER TANK-3 FEET†

Specifications: Concrete minimum strength-5000 psi at 28 days
Air entrainment - minimum 5%
Reinforcement- Base: Euclid Tuf Strand SF Fiber (6lbs./yd), #3 Grade 60 deformed rebar
Lid: #4 Grade 60 deformed rebar
Pipe connections - Polylok seals (patented)
Baffles - Plastic inlet
WEO312M Gould Pump,check valve,ball valve,float bracket,lift out cable,slide rail w/lift out adaptor,outdoor control panel w/alarm

DRAW DOWN IS 260 GALLONS

THOMPSON PLAZA UPGRADE†

9/1/07